2015 JUL -2 AM 8: 06

MISSISSIPPI STATE DEPARTMENT OF HEALTH BUREAU OF PUBLIC WATER SUPPLY CCR CERTIFICATION CALENDAR YEAR 2014 Delic Water Supply Name List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community public water system to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must mail, fax or

eman a copy of the CCR and Certific			
Customers were informed of a	vailability of CCR by: (Attach	copy of publication, water bill (	or other)
☐ Advertisem ☐ On water b ☐ Email mess	eent in local paper (attach copy ills (attach copy of bill) age (MUST Email the message	of advertisement)	·
Date(s) customers were infor	med:/_/	1	•
CCR was distributed by U.S. methods used	Postal Service or other dire	ct delivery. Must specify other	er direct delivery
Date Mailed/Distributed: 6	125 15		
CCR was distributed by Email  O As a URL (I  As an attach	ment		
	in the hody of the email messa,		
CCR was published in local nev			on)
Name of Newspaper:			
Date Published:			<del></del>
CCR was posted in public place	s. (Attach list of locations)	Date Posted: /	1
CCR was posted on a publicly a			
CERTIFICATION I hereby certify that the 2014 Consumpublic water system in the form and the SDWA. I further certify that the the water quality monitoring data Department of Health, Bureau of Publisher	information included in this (	) has been distributed to the coll that I used distribution meth CCR is true and correct and is an array system officials by the M	ustomers of this ods allowed by consistent with ississippi State
Ham Survayor, Owner, es	x.)	6-30-15 Daile	
Deliver or send via U.S. Postal Service: Bureau of Public Water Supply P.O. Box 1780 Jackson, MS 39215		May be faxed to: (601)576-7800 Man be smalled to:	
		water reports@madh.ms.gov	

2015 JUL -2 MI SI DE

# LAKE CITY WATER WEST 820015-01/02 (1) 8: 06

#### Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providiffy you with information because informed customers are our best allies.

### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

### Where does my water come from?

OUR WATER SOURCE IS A WELL ON HIGHWAY 16 WEST AT BAYLAND AND THE OTHER ON HIGHWAY 16 WEST NEAR HOLLYBLUFF, MS. OUR WATER IS DRAWN FROM THE AQUIFER, SPARTA SANDS.

### Source water assessment and its availability

WE HAVE A SOURCE WATER ASSESSMENT PLAN AVAILABLE AT OUR OFFICE THAT PROVIDES MORE INFORMATION SUCH AS POTENTIAL SOURCES OF CONTAMINATION. WE ARE AT A LOWER RISK AT THE BAYLAND WELL AND A LOWER RISK AT THE WELL NEAR HOLLYBLUFF.

### Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salis and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater-discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

# Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more perfectly of the proper of the contamination and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

	MCEG or <u>MRDLG</u>			0.0000000000000000000000000000000000000	nge High	Sample <u>Date</u>	<u>Violatio</u>	on Typical Source
Disinfectants & Disinfectant By-Products  (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants).								
	vicience the	it additic	n of a dis	intect	ant is i	lecessary	tor contro	By-product of drinking water
Haloacetic Acids (HAA5) (ppb)	NA	60	10	NA		2014	No	chlorination water
TTHMs [Total Trihalomethanes] (ppb)	NA	80	15.9	NA		2014	No	By-product of drinking water disinfection
Clilorine (as Cl2) (ppm)	4	4	2	1.5	2.8	2014	No	Water additive used to control microbes
Inorganie Contamina	ints							
Fluoride (ppm)	4	4	1.3	0.7	1.3	2014	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Barium (ppm)	. 2	2	0.0044	0.001	0.004	4 2013	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	100	100	0.0013	ND	0.001	3 2013	No	Discharge from steel and pulp mills; Erosion of natural deposits
Nitrate [measured as Nitrogen] (ppm)	10	10	0.08	ND	0.08	2014	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrite [measured as Nitrogen] (ppm)	1	1	0.02	NA		2014	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Contaminants	MCLG	Ale	Your Water	Sam <u>D</u> a		# Sampl exceeding	265 Tel 1880 S	cecus AL Typical Source
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	0.1	20	14	0	1	Corrosion of household No plumbing systems; Erosion of natural deposits

Unit Descriptions

YOU MAY CALL OUR OFFICE AT ANY TIME FOR ANY QUESTIONS YOU MAY HAVE. OUR NUMBER IS 662-746-2189, YOU MAY ALSO ATTEND OUR ANNUAL MEETING WHICH IS HELD IN FEBRUARY. YOU WILL BE NOTIFIED BY MAIL IN YOUR JANUARY BILL FOR THE TIME AND PLACE. THANK YOU FOR AYING YOUR BILL PROMPTLY. WE WANT TO REMIND YOU TO CALL US IF YOU NOTICE A LEAK ON YOUR WATER SYSTEM. SHOULD YOU EXPERIENCE LOW PRESSURE OR NO WATER, PLEASE BOIL ALL YOUR DRINKING WATER AND CALL US ABOUT THE PROBLEM. WE WILL CATCH SAMPLES AND TRY TO CLEAR UP THE SYSTEM. IT WILL BE 5 TO 6 DAYS TO GET THE RESULTS OF THE WATER SAMPLES. PLEASE CALL US TO GET THIS REPORT.

### Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

#### Other Information

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", LAKE CITY WATER ASSN-WEST is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.7-1.3 ppm was 0. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.7-1.3 ppm was 0 %.

### Significant Deficiency Summary Report

During a sanitary survey conducted on 3/12/2012, the Mississippi State Department of Health cited the following significant deficiency(s) at Holly Bluff Waterworks Inc. System I.D. #820007. Lake City Water took over this system in September of 2013.

- 1. Well near-source of fecal contamination (ex. Septic system, sewer lines
- 2. Improper record keeping
- 3. Not monitoring according to site sampling plan or monitoring plan
- 4. Inadequate security measures.

MSDH is currently working with this system to return them to compliance since the expiration of the compliance deadline. We anticipate the system being returned to compliance by 9/30/2015.

44...

## Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lake City Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Land Balablas Water Balling	
Important Drinking Water Definitions Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level